

$$A_p = A_s * \frac{T_o}{2\pi * \tau_p}$$

A_p = amplitude of primary process variable (%)

A_s = amplitude of oscillation in secondary process variable (%)

T_o = period of oscillation in secondary process variable (sec)

τ_p = time constant of primary process variable (sec)